

FLANGE PEQ REPORT: Flange (Equiv Pressure Method)

CASE 1 (OPE) W+T1+P1

Node	Axial Force N.	Bending Moment N.m.	G/C mm.	P Equivalent KPa	Rating Temperature e C	Allowable Pressure /Stress	Ratio %
10	73751	175320	971.55	12723.14	15.00	15306.36	83.12
20	73751	170801	971.55	12698.05	15.00	15306.36	82.96

FLANGE PEQ REPORT: Flange (Equiv Pressure Method)

CASE 11 (OCC) W+T1+P1+U1

Node	Axial Force N.	Bending Moment N.m.	G/C mm.	P Equivalent KPa	Rating Temperature e C	Allowable Pressure /Stress	Ratio %
10	5087	163521	971.55	12564.99	15.00	17602.31	71.38
20	30197	162065	971.55	12590.78	15.00	17602.31	71.53